

ANNEX 3

HEALTH & SAFETY TRACKING – RIDDOR (Reporting of Injuries, Disease and Dangerous Occurrence Regulations) INCIDENTS

The following are the incidents from 01/01/23 to 31/03/2023 reported to the Health & Safety Executive under the RIDDOR regulations

Ref: 28397 – Barnsley Interchange – 03/02/2023

A young male child trapped his fingers in the recess of the lift doors. The child was given a plaster by contract staff on site and the mother advised to take him to the local hospital to be checked out.

There have been a number of incidents with small children putting their fingers into the recess of the doors. Steps have been taken to try to eradicate the risk, including extra signage, frosting of the bottom section of the glass to stop children leaning to look out etc but, due to the design of the lift, it is very difficult.

Ref: 28418 – Meadowhall Interchange – 04/03/2023

An elderly female mis-stepped on the stairs to the lower mall and her foot slipped over the edge of the step causing her to fall. She fell approximately 5 feet from the step to the ground floor and, as she fell forward, she twisted and fell backwards hitting her head. An ambulance was called by a member of the public and our contract staff applied gauze to the back of the female's head to stem the bleeding until the ambulance arrived some 3 hours later. The ambulance staff assessed the female and took her to the local hospital. The area was checked for defects but nothing was found.